



Source of Sample: - Khowai Govt English Medium H.S School.
Date of receipt of Sample:- 27/08/2026
Date of Testing:- 28/08/2026

Sl. No	Name of Parameter	Desirable limit (Unit in mg/l)	Permissible Limit (Unit in mg/l)	Result		Remarks
				Raw water	Filter water	
1	Physical appearance	-	-	Clear	-	
2	Taste & Odour	Unobjectionable /Agreeable	-	Agreeable	-	
3	Turbidity in NTU	1 NTU	5 NTU	1.82	-	
4	pH	6.5-8.5	No Relaxation	6.80 at 25.2 ^o C	-	
5	Total Alkalinity as CaCO ₃ in mg/L.	200	600	24	-	
6	Total Hardness as CaCO ₃ in mg/L.	200	600	64	-	
7	Chloride as Cl in mg/L.	250	1000	-	-	
8	Residual Chlorine as Cl in mg/L. (ppm)	0.2	-	-	-	
9	Total Dissolved Solid in mg/L.	500	2000	-	-	
10	Total Iron as Fe in mg/L.	0.3 mg/l	No Relaxation	0.112	-	
11	Arsenic as in mg/L.	0.05	0.05	-	-	
12	Sulphate as SO ₄ in mg/L.	200	400	-	-	
13	Fluoride as F in mg/L.	1	1.5	-	-	
14	Nitrate as NO ₃ in mg/L.	45	100	-	-	
15	Total Coliform Bacteria	-	-	-	-	


Sr. Research Assistant
DWS Sub-Division Khowai
Khowai Tripura


Assistant Engineer
DWS Sub-Division, Khowai
Khowai Tripura

No.F.1 (29)-GEN/MS/KHW/2015 /10067
GOVERNMENT OF TRIPURA
OFFICE OF THE MEDICAL SUPERINTENDENT
KHOWAI DISTRICT HOSPITAL
KHOWAI: TRIPURA

Dated, Khowai 25/08/2026

TO WHOM IT MAY CONCERN


This is to certify that periodic health check-ups of the students of Khowai Govt. English Medium Class XII School, Khowai, Tripura is conducted regularly by Khowai District Hospital.

The health check-ups include general health assessment, screening for common ailments, monitoring of students health conditions, and referral of students requiring further medical evaluation and treatment at appropriate healthcare facilities whenever necessary.

It is further certified that necessary medical support and guidance are provided to the institution for ensuring good health and well-being of its students.

This certificate is issued on the request of the principal, Khowai Govt. English Medium Class XII School, Khowai, for official purpose.

To
The Principal
Khowai Govt. English Medium Class XII School
Khowai, Tripura


Medical Superintendent
Khowai District Hospital
Khowai: Tripura



Office of the
Khowai Municipal Council
Khowai, Tripura.


No. 8418 /F.5(54-A)/KMC/KH/SWM/2024, Dated, Khowai the 19.11.2024.

Sanitation Certificate

To Whom It May Concern :

Certified that the sanitation system including Drinking Water arrangement of '**Khowai Govt. English Medium Class-XII School**', Khowai, Tripura is being maintained properly, hygienically and safely. As such, the Khowai Municipal Council has got no objection to run the '**Khowai Govt. English Medium Class-XII School**', under the following terms and conditions:

1. That the certificate is issued as renewal of the previous Certificate No. 1184/F.5(54-A)/KMC/KH/SWM/2081, dt. 11-03-2022.
2. That the Certificate is valid only for one year from the date of issue (i.e. from 19/03/2024).
3. That in case of any complaints regarding Nuisance/ Health hazard / sanitary defects are noticed, the validity of the Certificate may be called off at any time even before the date of expiry.
4. That the proper methods and manner of Hygienic disinfections must be ensured.
5. That the admissible process as specified in related rules for Management of Wastes (Bio-Degradable or Non-degradable) is to be followed strictly.


Dy. Chief Executive Officer
Khowai Municipal Council.